




Air Conditioner ERP Test Report	
Report Number	4925118.50
Tested by (name + signature)	Linda Li <i>Linda Li</i>
Approved by (name + signature)	Jacky Zhang <i>Jacky Zhang</i>
Date of issue	2024-10-09
Total number of pages	20 Pages
Testing Laboratory	DEKRA Testing and Certification (Shanghai) Ltd., Guangzhou branch
Address	Block 5, No.3, Qiyun Road, Huangpu District, Guangzhou, Guangdong, China
Applicant's name	TCL Air conditioner (Zhong Shan) Co.,Ltd.
Address	No.59.Nantou Road West, Nantou Town Zhongshan City, Guangdong P.R. China
Test specification:	
Standard	EN 14511-1:2022, EN 14511-2:2022, EN 14511-3:2022, EN 14511-4:2022, EN 14825:2022, EN 12102-1:2022
Test procedure	(EU) No 206/2012, (EU) No 626/2011, EU 2017/254, EU 2016/2282, (EU) 2023/2048
Non-standard test method	N/A
Test Report Form No. EU AC 206 VERSION1.0	
Test Report Form(s) Originator	DEKRA
Test item description Air conditioner	
Trade Mark	TCL
Manufacturer	TCL Air Conditioner (Zhong Shan) Co., Ltd.
Factory	TCL Air Conditioner (Zhong Shan) Co., Ltd.
Model/Type reference	TAC-09CHSD/*I (* = HA/IA/KA/HC/KC/HD/KD/KE/LF/IF/KF/XA11/XA21/XA31/XA41/XA51/XA61/XA71/XA81/XA91/XAA1/XAB1/XAC1/XAD1/YA11/YA21/YA31/TP11/TP21/TP31/TP41/TP51/TP61/TPG1)
Ratings	220-240 V~, 50 Hz, see rating label


Summary of testing:
Tests performed (Test items): Cooling capacity Heating capacity Standby/off, thermostat off mode power consumption
Testing location: TCL Air conditioner (Zhong Shan) Co.,Ltd. No.59.Nantou Road West, Nantou Town Zhongshan City, Guangdong P.R. China
TAC-09CHSD/*I * can be HA/IA/KA/HC/KC/HD/KD/JE/KE/LF/IF/KF/XA11/XA21/XA31/XA41/XA51/XA61/XA71/XA81/XA91/XAA1/XAB1/XAC1/XAD1/YA11/YA21/YA31/TP11/TP21/TP31/TP41/TP51/TP61/TPG1 means different appearance and colour. This report is based on the original report No. 4382253.52,they are same except the version number of standard. After reviewed, there's no test should be added.

Copy of marking plate:

The artwork below may be only a draft. The use of certification marks on a product must be authorized by the respective NCBs that own these marks.

TCL					
SPLIT TYPE AIR CONDITIONER					
Model	TAC-09CHSD/XAC11				
	Indoor	TAC-09CHSD/XAC11			
	Outdoor	TAC-09CHSD/XAC11			
		Cooling	Heating		
Capacity		2600W (940~3300)	2610W (940~3360)		
Current		4.0A (1.2~8.0)	3.8A (1.2~9.0)		
Rated Current (IEC/EN60335)		8.0A	9.0A		
Power Input		825W (240~1380)	767W (240~1552)		
Rated Power Input (IEC/EN60335)		1380W	1552W		
Indoor Air Volume		420m³/h	420m³/h		
Maximum Allowable Pressure			3.7MPa		
Max. Pressure	Discharge		3.7MPa		
	Suction		1.2MPa		
Sound Power	Indoor		50dB(A)		
	Outdoor		60dB(A)		
Weight	Indoor		7.5kg		
	Outdoor		22kg		
Rated Voltage			220-240V~		
Rated Frequency			50Hz		
Refrigerant/Charge/GWP			R32/0.490kg/675		
CO ₂ equivalent			0.331 tonnes		
Contains fluorinated greenhouse gases					
Outdoor Unit Water Proof Protection			IPX4		
TCL Air conditioner (Zhong Shan) Co., Ltd No. 59, Nantou Road West, Nantou, Zhongshan, Guangdong, China					

Rating label



Energy label

Test item particulars :	
Classification of installation and use	Fixed appliance
Supply Connection	Non-detachable power supply cord with plug

Possible test case verdicts:	
- test case does not apply to the test object..... :	N/A
- test object does meet the requirement	P (Pass)
- test object does not meet the requirement	F (Fail)
Testing :	
Date of receipt of test item	2024-07-15
Date (s) of performance of tests	2024-07-15 to 2024-08-19

General remarks:
<p>The test results presented in this report relate only to the object tested.</p> <p>This report shall not be reproduced, except in full, without the written approval of the Issuing testing laboratory.</p> <p>"(see Enclosure #)" refers to additional information appended to the report.</p> <p>"(see appended table)" refers to a table appended to the report.</p> <p>Throughout this report, a dot is used as the decimal separator.</p> <p>The measurement result is considered in conformance with the requirement if it is within the prescribed limit, It is not necessary to calculate the uncertainty associated with the measurement result.</p> <p>The test results presented in this report relate only to the object tested.</p> <p>The information provided by the customer in this report may affect the validity of the results, the test lab is not responsible for it.</p> <p>This report shall not be reproduced, except in full, without the written approval of the Issuing testing laboratory.</p> <p>This report is not used for social proof function in China market.</p>

General product information:	
Model number of Unit Under Test	TAC-09CHSD/XAC1I
Type of System	Split type air conditioner
Air-conditioner Type	Cooling and heating
Power Supply	Single Phase
Refrigerant	R32
Unit Mounting (applicable to non ducted indoor units only)	Wall mounted
Heat Source (Heating Mode)	Air
Heat Sink (Cooling Mode)	Air-cooled
Does this air conditioner have a variable output compressor?	Yes
Type of compressor	inverter
Maximum continuous frequency for cooling (applicable to inverter driven compressor only) (Hz)	65
Maximum continuous frequency for heating (applicable to inverter driven compressor only) (Hz)	91

Test and verification results			
Clause	Ecodesign requirements - GENERIC ECODESIGN REQUIREMENTS	Result - Remark	Verdict
2a)	From 1 January 2013: Single duct and double duct air conditioners shall correspond to requirements as indicated in Tables 1, 2 and 3		N/A
Table 1	Requirements for minimum energy efficiency		N/A
Table 2	Off mode: Power consumption of equipment in any off-mode condition shall not exceed 1,00 W		N/A
	Standby mode: The power consumption of equipment in any condition providing only a reactivation function, or providing only a reactivation function and a mere indication of enabled reactivation function, shall not exceed 1,00 W.		N/A
	Standby mode: The power consumption of equipment in any condition providing only information or status display, or providing only a combination of reactivation function and information or status display, shall not exceed 2,00 W.		N/A
	Availability of standby and/or off mode Equipment shall, except where this is inappropriate for the intended use, provide off mode and/or standby mode, and/or another condition which does not exceed the applicable power consumption requirements for off mode and/or standby mode when the equipment is connected to the mains power source.		N/A
Table 3	Indoor sound power level no more than 65 dB(A)		N/A
2b)	From 1 January 2013, air conditioners, except single and double duct air conditioners, shall correspond to minimum energy efficiency and maximum sound power level requirements as indicated in Tables 4 and 5		N/A
Table 4	Requirements for minimum energy efficiency		P
Table 5	Requirements for maximum sound power level		P
2c)	From 1 January 2014, air conditioners shall correspond to requirements as indicated in the table 6		P
2d)	From 1 January 2014, single duct and double duct air conditioners and comfort fans shall correspond to requirements as indicated in Table 7		N/A
Table 7	Off mode: Power consumption of equipment in any off-mode condition shall not exceed 0,50 W.		N/A

Clause	Ecodesign requirements - GENERIC ECODESIGN REQUIREMENTS	Result - Remark	Verdict
	Standby mode: The power consumption of equipment in any condition providing only a reactivation function, or providing only a reactivation function and a mere indication of enabled reactivation function, shall not exceed 0,50 W.		N/A
	Standby mode: The power consumption of equipment in any condition providing only information or status display, or providing only a combination of reactivation function and information or status display shall not exceed 1,00 W.		N/A
	Availability of standby and/or off mode Equipment shall, except where this is inappropriate for the intended use, provide off mode and/or standby mode, and/or another condition which does not exceed the applicable power consumption requirements for off mode and/or standby mode when the equipment is connected to the mains power source.		N/A
	Power management When equipment is not providing the main function, or when other energy- using product(s) are not dependent on its functions, equipment shall, unless inappropriate for the intended use, offer a power management function, or a similar function, that switches equipment after the shortest possible period of time appropriate for the intended use of the equipment, automatically into: — standby mode, or — off mode, or — another condition which does not exceed the applicable power consumption requirements for off mode and/or standby mode when the equipment is connected to the mains power source. The power management function shall be activated before delivery.		N/A

Information requirements for air conditioners, except double duct and single duct air conditioners							
Function (indicate if present)				If function includes heating: Indicate the heating season the information relates to. Indicated values should relate to one heating season at a time. Include at least the heating season 'Average'.			
cooling	Y			Average (mandatory)	Y		
heating	Y			Warmer (if designated)	Y		
				Colder (if designated)	N		
Item	symbol	value	unit	Item	symbol	value	unit
Design load				Seasonal efficiency			
cooling	Pdesignc	2.6	kW	cooling	SEER	6.1	—
heating/Average	Pdesignh	2.0	kW	heating/Average	SCOP/A	4.0	—
heating/Warmer	Pdesignh	2.2	kW	heating/Warmer	SCOP/W	5.1	—
heating/Colder	Pdesignh	-	kW	heating/Colder	SCOP/C	-	—
Declared capacity (*) for cooling, at indoor temperature 27(19) °C and outdoor temperature Tj				Declared energy efficiency ratio (*), at indoor temperature 27(19) °C and outdoor temperature Tj			
Tj = 35 °C	Pdc	2.60	kW	Tj = 35 °C	EERd	3.04	—
Tj = 30 °C	Pdc	1.94	kW	Tj = 30 °C	EERd	5.22	—
Tj = 25 °C	Pdc	1.24	kW	Tj = 25 °C	EERd	8.19	—
Tj = 20 °C	Pdc	0.72	kW	Tj = 20 °C	EERd	10.53	—
Declared capacity (*) for heating/Average season, at indoor temperature 20°C and outdoor temperature Tj				Declared coefficient of performance (*)/Average season, at indoor temperature 20°C and outdoor temperature Tj			
Tj = − 7 °C	Pdh	1.77	kW	Tj = − 7 °C	COPd	2.66	—
Tj = 2 °C	Pdh	1.16	kW	Tj = 2 °C	COPd	4.13	—
Tj = 7 °C	Pdh	0.76	kW	Tj = 7 °C	COPd	4.80	—
Tj = 12 °C	Pdh	0.82	kW	Tj = 12 °C	COPd	6.22	—
Tj = bivalent temperature, - 7 °C	Pdh	1.77	kW	Tj = bivalent temperature	COPd	2.66	—
Tj = operating limit, -15°C	Pdh	1.99	kW	Tj = operating limit	COPd	2.51	—
Declared capacity (*) for heating/Warmer season, at indoor temperature 20°C and outdoor temperature Tj				Declared coefficient of performance (*)/Warmer season, at indoor temperature 20°C and outdoor temperature Tj			
Tj = 2 °C	Pdh	2.20	kW	Tj = 2 °C	COPd	2.82	—
Tj = 7 °C	Pdh	1.55	kW	Tj = 7 °C	COPd	5.29	—
Tj = 12 °C	Pdh	0.77	kW	Tj = 12 °C	COPd	5.94	—
Tj = bivalent temperature	Pdh	2.20	kW	Tj = bivalent temperature	COPd	2.82	—

T _j = operating limit	P _{dh}	2.20	EN 14511: 2013+ EN 14825: 2016	T _j = operating limit	COP _d	2.82	—
Declared capacity (*) for heating/Colder season, at indoor temperature 20°C and outdoor temperature T _j				Declared coefficient of performance (*) /Colder season, at indoor temperature 20°C and outdoor temperature T _j			
T _j = - 7 °C	P _{dh}	N/A	kW	T _j = - 7 °C	COP _d	N/A	—
T _j = 2 °C	P _{dh}	N/A	kW	T _j = 2 °C	COP _d	N/A	—
T _j = 7 °C	P _{dh}	N/A	kW	T _j = 7 °C	COP _d	N/A	—
T _j = 12 °C	P _{dh}	N/A	kW	T _j = 12 °C	COP _d	N/A	—
T _j = bivalent temperature	P _{dh}	N/A	kW	T _j = bivalent temperature	COP _d	N/A	—
T _j = operating limit	P _{dh}	N/A	kW	T _j = operating limit	COP _d	N/A	—
T _j = - 15 °C	P _{dh}	N/A	kW	T _j = - 15 °C	COP _d	N/A	—
Bivalent temperature				Operating limit temperature			
heating/Average	T _{biv}	-7	°C	heating/Average	T _{ol}	-15	°C
heating/Warmer	T _{biv}	2	°C	heating/Warmer	T _{ol}	2	°C
heating/Colder	T _{biv}	N/A	°C	heating/Colder	T _{ol}	N/A	°C
Cycling interval capacity				Cycling interval efficiency			
for cooling	P _{cycc}	N/A	kW	for cooling	EER _{cyc}	N/A	—
for heating	P _{cyh}	N/A	kW	for heating	COP _{cyc}	N/A	—
Degradation co-efficient cooling (**)	C _{dc}	0.25	—	Degradation co-efficient heating (**)	C _{dh}	0.25	—
Electric power input in power modes other than 'active mode'				Annual electricity consumption			
off mode	POFF	—	kW	cooling	QCE	149	kWh/a
standby mode	PSB	0.005	kW	heating/Average	QHE	700	kWh/a
thermostat-off mode	PTO	0.020	kW	heating/Warmer	QHE	604	kWh/a
crankcase heater mode	PCK	—	kW	heating/Colder	QHE	—	kWh/a
Capacity control (indicate one of three options)				Other items			
fixed	N			Sound power level (indoor/outdoor)	LWA	50/60	dB(A)
staged	N			Global warming potential	GWP	675	kgCO ₂ eq.
variable	Y			Rated air flow (indoor/outdoor)	—	550/1700	m ³ /h

Information requirements for single duct and double duct air conditioners.			
Information to identify the model(s) to which the information relates to [fill in as necessary]			
Description	Symbol	Value	Unit
Rated output power for cooling	P_{rated} for cooling	N/A	kW
Rated output power for heating	P_{rated} for heating	N/A	kW
Rated power input for cooling	P_{EER}	N/A	kW
Rated power input for heating	P_{COP}	N/A	kW
Rated Energy efficiency ratio	EER_{rated}	N/A	—
Rated Coefficient of performance	COP_{rated}	N/A	—
Thermostat-off mode power consumption	P_{TO}	N/A	W
Standby mode power consumption	P_{SB}	N/A	W
Off mode power consumption	P_{OFF}	N/A	W
Seasonal electricity consumption for double ducts (DD): hourly electricity consumption for single ducts (SD): hourly electricity consumption	Q	N/A	kWh/60min.
Sound power level (indoor only)	L_{WA}	N/A	dB(A)
Global warming potential of refrigerant	GWP	N/A	kgCO ₂ eq.
Contact details for obtaining more information	N/A		

Table for cooling test data

General test conditions/part load	unit	A35/A27(100%)	A30/A27(74%)	A25/A27(47%)	A20/A27(21%)
-	-	A	B	C	D
Barometric	kPa	100.99	100.84	101.46	100.90
Voltage	V	230.6	229.6	230.3	229.69
Current input	A	3.78	2.53	1.06	0.40
Power input	kW	0.856	0.372	0.151	0.068
Test conditions indoor unit					
Air inlet temperature, DB/WB	°C	27.08/19.07	26.99/18.97	26.95/19.03	26.96/19.05
Air outlet temperature, DB/WB	°C	N/A	N/A	N/A	N/A
Test conditions outdoor unit					
Air inlet temperature, DB/WB	°C	35.05/23.95	29.94/24.94	24.95/15.03	19.99/13.98
Total cooling capacity	kW	2.603	1.943	1.237	0.716
Power input	kW	0.856	0.372	0.151	0.068
Energy efficiency ratio	-	3.04	5.22	8.19	10.53
Compressor frequency	Hz	65	36	19	10

Table for heating test data (Average)

General test conditions/ part load	unit	A-10/A20 (100%)	A-7/A20 (88%)	A-7/A20 (88%)	A2/A20 (54%)	A7/A20 (35%)	A12/A20 (15%)
-	-	E	F	A	B	C	D
Barometric	kPa	101.68	101.65	101.65	101.657	100.93	102.14
Voltage	V	230.25	230.45	230.45	230.20	230.01	229.82
Current input	A	3.50	2.92	2.92	1.84	1.13	0.92
Power input	kW	0.796	0.667	0.667	0.280	0.159	0.131
Test conditions indoor unit							
Air inlet temperature, DB/WB	°C	20.00/15.01	20.00/15.00	20.00/15.00	20.01/15.00	20.04/14.99	19.96/15.01
Air outlet temperature, DB/WB	°C	32.67/17.25	32.45/16.58	32.45/16.58	27.31/15.28	N/A	N/A
Test conditions outdoor unit							
Air inlet temperature, DB/WB	°C	-10.00/-10.99	-7.00/-8.01	-7.00/-8.01	2.00/1.00	7.00/6.01	12.04/11.01
Summary of the test results	-	A-10/A20 (100%)	A-7/A20 (88%)	A-7/A20 (88%)	A2/A20 (54%)	A7/A20 (35%)	A12/A20 (15%)
Total heating capacity	kW	1.998	1.774	1.774	1.156	0.763	0.815
Power input	kW	0.796	0.667	0.667	0.280	0.159	0.131
Co-efficiency of performance	-	2.51	2.66	2.66	4.13	4.80	6.22
Compressor frequency	Hz	91	72	72	31	20	16

Table for heating test data (Warmer)

General test conditions/part load	unit	--	--	--	A2/A20 (100%)	A7/A20 (64%)	A12/A20 (29%)
-	-	E	F	A	B	C	D
Barometric	kPa	101.55	101.55	--	101.55	101.35	102.05
Voltage	V	230.48	230.48	--	230.48	229.52	229.87
Current input	A	3.43	3.43	--	3.43	2.00	0.91
Power input	kW	0.780	0.780	--	0.780	0.293	0.129
Test conditions indoor unit							
Air inlet temperature, DB/WB	°C	19.99/14.99	19.99/14.99	--	19.99/14.99	20.02/14.99	20.04/15.03
Air outlet temperature, DB/WB	°C	34.11/19.71	34.11/19.71	--	34.11/19.71	N/A	N/A
Test conditions outdoor unit							
Air inlet temperature, DB/WB	°C	2.00/1.00	2.00/1.00	--	2.00/1.00	7.01/6.01	12.01/10.97
Summary of the test results	-	A2/A20 (100%)	A2/A20 (100%)	--	A2/A20 (100%)	A7/A20 (64%)	A12/A20 (29%)
Total heating capacity	kW	2.201	2.201	--	2.201	1.549	0.766
Power input	kW	0.780	0.780	--	0.780	0.293	0.129
Co-efficiency of performance	-	2.82	2.82	--	2.82	5.29	5.94
Compressor frequency	Hz	72	72	--	72	36	16

SEER calculation:

	Outdoor air °C	measured Cooling Capacity kW	Input Power kW	EER _{DC/meas}	Cd	EER _{PL}
A	35	2.603	0.856	3.04	0.25	3.04
B	30	1.943	0.372	5.22	0.25	5.22
C	25	1.237	0.151	8.19	0.25	8.19
D	20	0.716	0.068	10.53	0.25	10.53

	Tj	Part load ratio	Cooling demand Pc(Tj)	Bin hours hj	Measured Cooling capacity	Capacity ratio	Measured EER	Corrected d EER _{PL}	EER(Tj) Cd=0,25	hj x Pc(Tj)	hj x Pc(Tj) / EERbin(Tj)
	17	5.3%	0.137	205					9.91	28	3
	18	10.5%	0.274	227					9.91	62	6
	19	15.8%	0.411	225					9.91	92	9
D	20	21.1%	0.548	225	0.716	0.765	10.53	9.91	9.91	123	12
	21	26.3%	0.685	216					9.57	148	15
	22	31.6%	0.822	215					9.22	177	19
	23	36.8%	0.959	218					8.88	209	24
	24	42.1%	1.096	197					8.54	216	25
C	25	47.4%	1.233	178	1.237	0.997	8.19	8.19	8.19	219	27
	26	52.6%	1.370	158					7.60	216	28
	27	57.9%	1.507	137					7.00	206	29
	28	63.2%	1.644	109					6.41	179	28
	29	68.4%	1.781	88					5.82	157	27
B	30	73.7%	1.918	63	1.943	0.987	5.22	5.22	5.22	121	23
	31	78.9%	2.055	39					4.79	80	17
	32	84.2%	2.192	31					4.35	68	16
	33	89.5%	2.329	24					3.91	56	14
	34	94.7%	2.466	17					3.48	42	12
A	35	100.0%	2.603	13	2.603	1.000	3.04	3.04	3.04	34	11
	36	105.3%	2.740	9					3.04	25	8
	37	110.5%	2.877	4					3.04	12	4
	38	115.8%	3.014	3					3.04	9	3
	39	121.1%	3.151	1					3.04	3	1
	40	126.3%	3.288	0					3.04	0	0
										2483	363
										SEERon	6.84
										SEER	6.14

Equiv. Hce	350	h				Q _c /SEER _{on}	133.1387
H _{TO}	221	h	P _{TO}	0.02	kW	HTO*PTO	4.42 kWh
H _{SB}	2142	h	P _{SB}	0.005	kW	HSB*PSB	10.71 kWh
H _{CK}	2672	h	P _{CK}	0	kW	HCK*PCK	0 kWh
H _{OFF}	0	h	P _{OFF}	0	kW	HOFF*POFF	0 kWh
						Q _{co}	148.2687
P _{designc}	2.603	kW					
Q _c	911.05	kWh					

SCOP calculation (Average):

	Outdoor air °C	measured Cooling Capacity kW	Input Power kW	COP _{DC/meas}	Cd	COP _{PL} (COP bin (T _j))
A	-7	1.774	0.667	2.66	0.25	2.66
B	2	1.156	0.280	4.13	0.25	4.13
C	7	0.763	0.159	4.80	0.25	4.80
D	12	0.815	0.131	6.22	0.25	6.22
E	-10	1.998	0.796	2.51	0.25	2.51
F	-7	1.774	0.667	2.66	0.25	2.66

	Tj	Part load ratio	Heating demand Ph(Tj)	Bin hours hj	Heat load covered by the heat pump elbu(Tj)	Capacity ratio	COP _{PL}	COP _{bin(Tj)}	hj x Ph(Tj)	h _j ² [(Ph(Tj)- elbu(Tj))/ COPbin(Tj)] +elbu(Tj)]	COP (including backup heater)	h _j ² [(Ph(Tj)- elbu(Tj))/ COPbin(Tj)]	h _j ² [(Ph(Tj)- elbu(Tj))/ COPbin(Tj)]
	-10	100.0%	2.005	1	1.998	0.007	1.00	2.51	2	1	2.50	2	0.80
	-9	96.2%	1.928	25	1.923	0.005	1.00	2.56	48	19	2.55	48	18.78
	-8	92.3%	1.851	23	1.849	0.002	1.00	2.61	43	16	2.60	43	16.29
A	-7	88.5%	1.774	24	1.774	0.000	1.00	2.66	43	16	2.66	43	16.01
	-6	84.6%	1.697	27	1.697	0.000	1.00	2.82	46	16	2.82	46	16.23
	-5	80.8%	1.620	68	1.620	0.000	1.00	2.99	110	37	2.99	110	36.89
	-4	76.9%	1.543	91	1.543	0.000	1.00	3.15	140	45	3.15	140	44.57
	-3	73.1%	1.465	89	1.465	0.000	1.00	3.31	130	39	3.31	130	39.37
	-2	69.2%	1.388	165	1.388	0.000	1.00	3.48	229	66	3.48	229	65.91
	-1	65.4%	1.311	173	1.311	0.000	1.00	3.64	227	62	3.64	227	62.34
	0	61.5%	1.234	240	1.234	0.000	1.00	3.80	296	78	3.80	296	77.90
B	1	57.7%	1.157	280	1.157	0.000	1.00	3.97	324	82	3.97	324	81.69
	2	53.8%	1.080	320	1.080	0.000	1.00	4.13	346	84	4.13	346	83.70
	3	50.0%	1.003	357	1.003	0.000	1.00	4.26	358	84	4.26	358	83.98
	4	46.2%	0.926	356	0.926	0.000	1.00	4.40	330	75	4.40	330	74.94
	5	42.3%	0.848	303	0.848	0.000	1.00	4.53	257	57	4.53	257	56.74
	6	38.5%	0.771	330	0.771	0.000	1.00	4.66	255	55	4.66	255	54.57
C	7	34.6%	0.694	326	0.694	0.000	1.00	4.80	226	47	4.80	226	47.16
	8	30.8%	0.617	348	0.617	0.000	1.00	4.89	215	44	4.89	215	43.91
	9	26.9%	0.540	335	0.540	0.000	1.00	4.98	181	36	4.98	181	36.31
	10	23.1%	0.463	315	0.463	0.000	1.00	5.07	146	29	5.07	146	28.74
	11	19.2%	0.386	215	0.386	0.000	1.00	5.16	83	16	5.16	83	16.06
D	12	15.4%	0.309	169	0.309	0.000	1.00	5.25	52	10	5.25	52	9.92
	13	11.5%	0.231	151	0.231	0.000	1.00	5.3460	35	7	5.35	35	6.54
	14	7.7%	0.154	105	0.154	0.000	1.00	5.4372	16	3	5.44	16	2.98
	15	3.8%	0.077	74	0.077	0.000	1.00	5.5285	6	1	5.53	6	1.03
16	0.0%			4910									
					0.015				summation	4142	1024	4142	1023
									SCOPon	4.05		SCOPnet	4.05
									SCOP	4.03			

H _{hc}	1400	h				Q _h /SCOP _{on}	693.71814	
H _{TD}	179	h	P _{TD}	0.02	kW	HTO*PTO	3.58	kwh
H _{SB}	0	h	P _{SB}	0.005	kW	HSB*PSB	0	kwh
H _{CK}	179	h	P _{CK}	0	kW	HCK*PCK	0	kwh
H _{OFF}	0	h	P _{OFF}	0	kW	HOFF*POFF	0	kwh
						Q _{h0}	697.29814	
P _{designh}	2.005	kW						
Q _h	2807.5478	kWh						

SCOP calculation (Warmer):

	Outdoor air °C	measured Cooling Capacity kW	Input Power kW	COP _{DC/meas}	Cd	COP _{PL} (COP bin (T _j))
B	2	2.201	0.780	2.82	0.25	2.82
C	7	1.549	0.293	5.29	0.25	5.29
D	12	0.766	0.129	5.94	0.25	5.94
E	2	2.201	0.780	2.82	0.25	2.82
F	2	2.201	0.780	2.82	0.25	2.82

										h _j		COP		h _j *[Ph(T _j)-	
										*[[[Ph(T _j)-		(including		h _j *[Ph(T _j)-	
										elbu(T _j)]/		backup		elbu(T _j)]/C	
										COPBin(T _j)-		heater		OPBin(T _j)]	
										*elbu(T _j)]					
										h _j x Ph(T _j)					
										COP _d		COP _{me} (T _j)			

Equiv. H	1400	h				Q _H /SCOP _{on} 588.038338		
H _{TO}	755	h	P _{TO}	0.02	kW	HTO*PTO	15.1	kwh
H _{SB}	0	h	P _{SB}	0.005	kW	HSB*PSB	0	kwh
H _{CK}	755	h	P _{CK}	0	kW	HCK*PCK	0	kwh
H _{OFF}	0	h	P _{OFF}	0	kW	HOFF*POFF	0	kwh
						Q _{he}	603.1383	
P _{designh}	2.201	kW						
Q _H	3081.4	kWh						

Item	Measured value	Rated value	Deviation	Verdict
SEER	6.14	6.1	0.7%	P
SCOP average	4.03	4.0	0.8%	P
SCOP warmer	5.11	5.1	0.2%	P
Power consumption in off mode	N/A	N/A	N/A	N/A
Power consumption in standby mode	5.00 W	5.00 W	0%	P
Remark: For the original qualification test, the rating values should be equal to or more unfavorable than the tested values.				

Table 1

Energy efficiency classes for air conditioners, except double ducts and single ducts

Energy Efficiency Class	SEER	SCOP
A+++	SEER $\geq 8,50$	SCOP $\geq 5,10$
A++	$6,10 \leq \text{SEER} < 8,50$	$4,60 \leq \text{SCOP} < 5,10$
A+	$5,60 \leq \text{SEER} < 6,10$	$4,00 \leq \text{SCOP} < 4,60$
A	$5,10 \leq \text{SEER} < 5,60$	$3,40 \leq \text{SCOP} < 4,00$
B	$4,60 \leq \text{SEER} < 5,10$	$3,10 \leq \text{SCOP} < 3,40$
C	$4,10 \leq \text{SEER} < 4,60$	$2,80 \leq \text{SCOP} < 3,10$
D	$3,60 \leq \text{SEER} < 4,10$	$2,50 \leq \text{SCOP} < 2,80$
E	$3,10 \leq \text{SEER} < 3,60$	$2,20 \leq \text{SCOP} < 2,50$
F	$2,60 \leq \text{SEER} < 3,10$	$1,90 \leq \text{SCOP} < 2,20$
G	SEER $< 2,60$	SCOP $< 1,90$

Table for sound power

indoor										
Test voltage / frequency	230 V / 50 Hz									
Air inlet temperature, DB/WB	27.0°C /19.0°C									
Measured surface	6.28 m ²									
Background Noise Level [dB]	18.0									
Microphone Position	1	2	3	4	5	6	7	8	9	10
L _{pi} [dB]	39.4	41.3	41.4	41.5	41.5	40.4	41.2	40.2	41.3	41.3
L _{pmc} / Averaged Sound Pressure Level [dB (A)]	41.00									
LW / Sound Power Level [dB (A)]	48.98									
Rated sound Power Level [dB (A)]	50									
Verdict	P									

outdoor					
Test voltage / frequency	230 V / 50 Hz				
Air inlet temperature, DB/WB	35.0 °C/24.0 °C				
Measured surface	12.32 m ²				
Background Noise Level [dB]	18.0				
Microphone Position	1	2	3	4	5
L _{pi} [dB]	47.1	47.3	48.1	47.7	46.3
L _{pmc} / Averaged Sound Pressure Level [dB (A)]	47.34				
LW / Sound Power Level [dB (A)]	58.25				
Rated sound Power Level [dB (A)]	60				
Verdict	P				


Photos:



Indoor unit



Outdoor unit



Compressor label

End of report